

<b>KLM Technology Group</b>  Project Engineering Standard	  <a href="http://www.klmtechgroup.com">www.klmtechgroup.com</a>	Page : 1 of 54
		Rev: 01
		April 2011
KLM Technology Group #03-12 Block Aronia, Jalan Sri Perkasa 2 Taman Tampoi Utama 81200 Johor Bahru Malaysia	<b>PROCESS REQUIREMENTS          OF HEAT EXCHANGING EQUIPMENT          (PROJECT STANDARDS AND SPECIFICATIONS)</b>	

## TABLE OF CONTENT

<b>SCOPE</b>	<b>3</b>
<b>REFERENCES</b>	<b>3</b>
<b>DEFINITIONS AND TERMINOLOGY</b>	<b>3</b>
<b>SYMBOLS AND ABBREVIATIONS</b>	<b>7</b>
<b>UNITS</b>	<b>8</b>

## PROCESS DESIGN OF SHELL AND TUBE HEAT EXCHANGERS

<b>General Considerations</b>	<b>9</b>
<b>GENERAL REQUIREMENTS</b>	<b>13</b>
<b>Fluid Allocation</b>	<b>13</b>
<b>Installation</b>	<b>14</b>
<b>Nozzle Location</b>	<b>14</b>
<b>Impingement Baffles and Erosion Protection</b>	<b>15</b>
<b>Geometrical</b>	<b>17</b>
<b>BASIC RELATIONS</b>	<b>24</b>
<b>Fluid Temperature Relations</b>	<b>24</b>
<b>Fouling</b>	<b>24</b>
<b>THERMAL DESIGN</b>	<b>29</b>
<b>Pressure Drop</b>	<b>29</b>
<b>Design Velocities</b>	<b>29</b>
<b>Exchanger Design Pressures and Temperatures</b>	<b>29</b>

<b>KLM Technology Group</b>  Project Engineering Standard	<b>PROCESS REQUIREMENTS OF HEAT EXCHANGING EQUIPMENT</b>  <b>(PROJECT STANDARDS AND SPECIFICATIONS)</b>	Page 2 of 54
		Rev: 01
		April 2011

**PROCESS DESIGN OF PLATE HEAT EXCHANGERS  
(PLATE FIN EXCHANGERS)**

<b>PLATE FIN EXCHANGERS</b>	<b>32</b>
<b>APPLICATION</b>	<b>32</b>
<b>MATERIAL</b>	<b>35</b>
<b>CONSTRUCTION</b>	<b>35</b>
<b>ADVANTAGES</b>	<b>36</b>
<b>DISADVANTAGES</b>	<b>36</b>
<b>DESIGN CONSIDERATIONS (PLATE FIN EXCHANGERS)</b>	<b>37</b>
Exchanger Geometry	<b>37</b>
<b>APPENDIX A</b>	<b>46</b>
<b>APPENDIX B</b>	<b>47</b>
<b>APPENDIX C</b>	<b>49</b>

<b>KLM Technology Group</b>  Project Engineering Standard	<b>PROCESS REQUIREMENTS OF HEAT EXCHANGING EQUIPMENT</b>  <b>(PROJECT STANDARDS AND SPECIFICATIONS)</b>	Page 3 of 54
		Rev: 01
		April 2011

## SCOPE

This Project Standards and Specifications covers the minimum process design requirements, for thermal design, field of application, selection of types and hydraulic calculations for shell and tube heat exchangers, and plate heat exchangers (plate fin exchangers).

## REFERENCES

Throughout this Standard the following dated and undated standards/codes are referred to. These referenced documents shall, to the extent specified herein, form a part of this standard. For dated references, the edition cited applies. The applicability of changes in dated references that occur after the cited date shall be mutually agreed upon by the Company and the Vendor. For undated references, the latest edition of the referenced documents (including any supplements and amendments) applies.

1. TEMA (The Tubular Exchanger Manufacturers Association)
  - "Standards of the Tubular Exchanger Manufacturers Association (TEMA)" 9th Ed.2007
2. API (American Petroleum Institute)
  - API Std. 660, "Shell & Tube Heat Exchangers for General Refinery Services" for General Refinery Services" 7th. Ed., April 2003, Reaffirmed Dec. 1987
  - API Std. 662 "Plate Heat Exchanger for General Refinery Services"
  - Part I- Plate-and Frame Heat Exchangers 1st.Ed.Feb.2006
  - API Std. 662 "Plate Heat Exchanger for General Refinery Services"
  - Part II- Brazed Aluminum Plate –Fin Heat Exchangers 1st.Ed.Feb.2006

## DEFINITIONS AND TERMINOLOGY

**Chiller** - The chiller is a typical kettle type exchanger, and the bundles has tubes to a height of about 60 per cent of the diameter. The vapor space above is for disengagement of the vapor from the liquid. Chillers are used in refrigeration processes of the vapor-compression type. A chiller cools a fluid with a refrigerant to a temperature below that obtainable using air or cooling water as the heat sink. Common refrigerants are propane, ethylene and propylene; chilled water or brines are less frequently used.

<p style="text-align: center;"><b>KLM Technology Group</b></p> <p>Project Engineering Standard</p>	<p><b>PROCESS REQUIREMENTS OF HEAT EXCHANGING EQUIPMENT</b></p> <p><b>(PROJECT STANDARDS AND SPECIFICATIONS)</b></p>	Page 4 of 54
		Rev: 01
		April 2011

**Condenser** - A condenser is a unit in which a process vapor is totally or partially converted to liquid. The heat sink is ordinarily a utility, such as cooling water. The term "surface condenser" refers specifically to shell and tube units, used to condense the steam from a preceding ejector stage, thus reducing the inlet quantity of vapor mixture to the following stage. This is a means of increasing steam economy. They do not affect ejector performance, but they do avoid the nuisance of exhausting steam to the atmosphere, thus, they allow steam to be recovered. A "direct contact condenser" refers to a unit in which the vapor is condensed by direct contact heat exchange with droplets of water.

- **Surface condenser** - Surface condenser is to condense the exhaust steam from a steam turbine to obtain maximum efficiency and also to convert the turbine exhaust steam into pure water (referred to as steam condensate) so that it may be reused in the steam generator or boiler as boiler feed water.
  - **Purpose** - Surface condenser by condensing the steam exhaust of a turbine at a pressure below atmospheric pressure, the pressure drop between the inlet and exhaust of the turbine is increased, which increases the amount of heat available for conversion to mechanical power.
  - **Cooling medium** - Most of the heat liberated due to condensation of the exhaust steam is carried away by the cooling medium (water or air) used by the surface condenser.
  - **Shell** - For most water-cooled surface condensers, the shell is under vacuum during normal operating conditions. Surface condenser shell is fabricated from carbon steel plates and is stiffened as needed to provide rigidity for the shell. When required by the selected design, intermediate plates are installed to serve as baffle plates that provide the desired flow path of the condensing steam.
  - **Hotwell** - At the bottom of the shell, where the condensate collects, an outlet is installed. In some designs, a sump (often referred to as the hotwell) is provided. Condensate is pumped from the outlet or the hotwell for reuse as boiler feed water.
  - **Vacuum system** - For water-cooled surface condenser, the shell's internal vacuum is mostly commonly supplied by and maintained by an external steam jet ejector system. Such an ejector system uses steam as the motive fluid to remove any non-condensable gases that may be present in the surface condenser.  
Motor driven mechanical vacuum pumps such as liquid ring type vacuum pumps, are also popular for vacuum service.

<b>KLM Technology Group</b>  Project Engineering Standard	<b>PROCESS REQUIREMENTS OF HEAT EXCHANGING EQUIPMENT</b>  <b>(PROJECT STANDARDS AND SPECIFICATIONS)</b>	Page 5 of 54
		Rev: 01
		April 2011

- **Tube sheets** - At each end of the shell, a sheet of sufficient thickness usually made of stainless steel is provided, with holes for the tubes to be inserted and rolled.
- **Tubes** - Generally the tubes are made of stainless steel, copper alloys such as brass or bronze, cupro nickel or titanium depending on several selection criteria. The use of copper bearing alloys such as brass or cupro nickel is rare in new plants, due to environmental concerns of toxic copper alloys. Also depending on the steam cycle water treatment for the boiler, it may be desirable to avoid tube materials containing copper. Titanium condenser tubes are usually the best technical choice; however, the use of titanium condenser tubes has been virtually eliminated by the sharp increase in the cost for this material.

The outer diameter of condenser tubes typically ranges from 19mm ( 3/4 inch) to 32mm (1-1/4 inch), based on condenser cooling water friction consideration and overall condenser size.

- **Waterboxes** - The tube sheet at each end with tube ends rolled for each end of the condenser is closed by a fabricated box cover known as waterbox, with flanged connection to the tube sheet or condenser shell. The waterbox is usually provided with manholes on hinged covers to allow inspection and cleaning.
- **Codes** - Steam surface condensers operate under a vacuum and are, therefore, not considered pressure vessels. The ASME Code is a pressure vessel code and is not, Strictly speaking, applicable to surface condensers operating under vacuum. However, the tube side of a surface condenser is considered a pressure vessel, as it is subjected to the full water pressure. When necessary, this side of the condenser can be designed and constructed to ASME Code requirement.

Most surface condensers are designed and constructed in accordance with HEI Standards.

**Cooler** - A cooler exchanges heat between a process stream and water or air.

**Evaporator** - Exchangers specifically designed to process fluid by some heating medium such as steam.

**Exchanger and/or heat exchanger** - In the broad sense, an exchanger is any item of unfired heat transfer equipment whose function is to change the total enthalpy of a stream. In the specific (and more usual) connotation, an exchanger transfers heat between two process streams.

<p style="text-align: center;"><b>KLM Technology Group</b></p> <p>Project Engineering Standard</p>	<p><b>PROCESS REQUIREMENTS OF HEAT EXCHANGING EQUIPMENT</b></p> <p><b>(PROJECT STANDARDS AND SPECIFICATIONS)</b></p>	Page 6 of 54
		Rev: 01
		April 2011

**Fouling resistance** - The fouling resistance is a measure of the ultimate additional resistance to heat transfer caused by deposits on and corrosion of the heat transfer material surface.

**Note:** The resistance depends on the type of fluid, the material, temperature conditions, flow velocities and the operating period between two successive cleaning actions.

**Fouling coefficient** - The fouling coefficient is the reciprocal of the fouling resistance.

**Note:** The use of the fouling coefficient has generally been abandoned, since it tends to be confusing that an increase in fouling results in a decrease in fouling coefficient.

**Reboiler** - reboiler is a vaporizer that provides latent heat of vaporization to the bottom (generally) of a fractionation tower. There are two general classes of reboilers, those which send both phases to the tower for separation of vapor from liquid and those which return only vapor. The former operate by either natural circulation (usually called thermosyphon) or forced circulation.

- Thermosyphon reboilers are by far the common type. Horizontal thermosyphons with vaporization on the shell side are commonly used in the petroleum industry while vertical units with in-tube vaporization are favored in the chemical industry. In a thermosyphon reboiler, sufficient liquid head is provided so that natural circulation of the boiling medium is maintained.
- Forced circulation reboilers require a pump to force the boiling medium through the exchanger. This type of reboiler is infrequently used because of the added cost of pumping the reboiler feed, but may be required to overcome hydrostatic head limitations and/or circulation problems.
- Reboilers which return only vapor to the tower are called kettle reboilers. The operation of kettle reboilers would be best described as pool boiling.

**Steam generators (waste heat boilers)** - Steam generators are a special type of vaporizer used to produce steam as the vapor product. Generally, the heat source is excess heat beyond that which is required for process; this accounts for the common name of "waste heat boiler" for these Units. Like reboilers, steam generators can be kettle, pump-through, or thermosyphon type.

**Superheater** - A superheater heats a vapor above its saturation temperature.

<b>KLM Technology Group</b>  Project Engineering Standard	<b>PROCESS REQUIREMENTS OF HEAT EXCHANGING EQUIPMENT</b>  <b>(PROJECT STANDARDS AND SPECIFICATIONS)</b>	Page 7 of 54
		Rev: 01
		April 2011

**TEMA "Class R" exchanger** - The TEMA Mechanical Standards for "Class R" heat exchanger specify design and fabrication of unfired shell and tube heat exchangers for the generally severe requirements of petroleum and related process application.

**TEMA "Class C" exchanger** - The TEMA Mechanical Standards for "Class C" heat exchangers specify design and fabrication of unfired shell and tube heat exchangers for the generally moderate requirements of commercial and general process application. "Class C" units are designed for maximum economy and result in a cost saving of about 5% over "Class R".

**TEMA "Class B" exchanger** - The TEMA Mechanical Standards for "Class B" heat exchangers specify design & fabrication of unfired shell & tube heat exchangers for chemical process service.

**Vaporizer** - A vaporizer is an exchanger which converts liquid into vapor. This term is sometimes limited to units handling liquids other than water.

## **SYMBOLS AND ABBREVIATIONS**

<b><u>SYMBOL/ABBREVIATION</u></b>	<b><u>DESCRIPTION</u></b>
A	Total exchanger area, (m <sup>2</sup> ).
A <sub>i</sub>	Required effective inside transfer surface, (m <sup>2</sup> ).
API	American Petroleum Institute.
Btu	British Thermal Unit.
CAF	Compressed Asbestos Fiber
DEA	Di – Ethanol Amine.
DGA	Di - Glycol Amine.
DN	Diameter Nominal, (mm).
DS	Design Pressure.
DS	Diameter of shell
EPDM	Ethylene Propylene Di Monomer.
F	LMTD Correction Factor
FPM	Fine Particular Matter.
h	Segment Opening Height
h <sub>f</sub>	Film coefficient of tube side fluid, in (W/m <sup>2</sup> .°C) or (W/m <sup>2</sup> .K)
ID	Inside Diameter, in (mm).
LMTD	Logarithmic Mean Temperature Difference.
MAWP	Maximum Allowable Working Pressure.

<b>KLM Technology Group</b>  Project Engineering Standard	<b>PROCESS REQUIREMENTS OF HEAT EXCHANGING EQUIPMENT</b>  <b>(PROJECT STANDARDS AND SPECIFICATIONS)</b>	Page 8 of 54
		Rev: 01
		April 2011

Max.	Maximum.
MEA	mono-Ethanolamine.
Min.	Minimum.
MOP	Maximum Operating Pressure.
MOT	Maximum Operating Temperature.
OD	Outside Diameter, (mm).
OGP	Oil, Gas and Petrochemical.
OP	Operating Pressure
PHE	Plate Heat Exchanger.
PSV	Pressure Safety Valve.
$r_i$	Fouling resistance on inside surface of tubes, (m <sup>2</sup> .°C/W).
$r_o$	Fouling resistance on outside surface of tubes, (m <sup>2</sup> .°C/W).
RCB	Resin Cured Butyl.
RGP	Recommended Good Practice.
SS	Stainless Steel.
TEMA	Tubular Exchanger Manufacturers Association.
V	Linear Velocity of the fluid, (m/s).
U	The overall heat transfer coefficient, (W/m <sup>2</sup> .°C) or (W/m <sup>2</sup> .K)
WC	Water Column, (mm).
$\rho$ (rho)	Density, (kg/m <sup>3</sup> ).

## UNITS

This Standard is based on International System of Units (SI) except where otherwise specified.

<b>KLM Technology Group</b>  Project Engineering Standard	<b>PROCESS REQUIREMENTS OF HEAT EXCHANGING EQUIPMENT</b>  <b>(PROJECT STANDARDS AND SPECIFICATIONS)</b>	Page 9 of 54
		Rev: 01
		April 2011

## PROCESS DESIGN OF SHELL AND TUBE HEAT EXCHANGERS

### General Considerations

1. The shell and tube type exchanger is commonly used in general petroleum processes. It is inexpensive, easy to clean, available in many sizes, and can be designed for moderate to high pressures at reasonable cost. It consists of a bundle of tubes encased in a shell.
2. Tubular units in general should have removable tube bundles and should be of the floating head type with removable shell covers.

Typical exceptions are:

- a. Fixed tube sheet exchangers such as refrigeration condensers and vacuum condensers.

In this type of construction, differential expansion of the shell and tubes due to different operating metal temperatures may require the use of an expansion joint or a packed joint.

- b. "U" tube type for reboilers using steam in the tube and for exchangers on hydrogen service. Removable shell covers are not required for this type.

Fluids having a fouling factor above  $-0.00035\text{m}^2.\text{K}/\text{W}$  ( $0.002\text{ hr}.\text{ft}^2.\text{°F}/\text{Btu}$ ) should be routed on the shell side of U-tube exchangers and on the tube side for floating head type exchangers. In all cases U-tubes should be located in the horizontal plane.

For chemical works, fixed head exchangers should be used when the shell side fluid is nonfouling. Where the shell side fluid is fouling. Utubes or floating head type bundles should be used and floating head type tube bundles when both sides are fouling.

Floating head type tube bundles are to be avoided for kettle type reboilers and chillers unless agreed by the Company.

3. There are two variations of floating tube sheet units, the pull-through and the non-pull-through. In the pullthrough unit, the entire floating tube sheet and cover assembly may be drawn through the shell without disassembly. In the non-pullthrough unit, the shell cover and the floating tube sheet cover must be removed before the bundle can be taken out of the shell.

This requirement is the greatest disadvantage of the non-pull-through unit. However, due to the smaller diameter tube sheet which is possible if a split ring assembly is used to fasten the floating head cover, the non-pull-through unit requires a smaller shell for the same surface.

<b>KLM Technology Group</b>  Project Engineering Standard	<b>PROCESS REQUIREMENTS OF HEAT EXCHANGING EQUIPMENT</b>  <b>(PROJECT STANDARDS AND SPECIFICATIONS)</b>	Page 10 of 54
		Rev: 01
		April 2011

4. Listing the above variations in shell and tube units in order of increasing cost would give the following tabulation:
  - a. Simple fixed tube sheet unit.
  - b. U-tube unit.
  - c. Fixed tube sheet unit with an expansion joint or packed joint.
  - d. Floating tube sheet unit (pull-through and non-pull-through).

Shell and tube type exchangers are usually fabricated to conform to "Class R" of the Standards of the Tubular Exchanger Manufacturers Association (TEMA).

5. The selection of TEMA "Class R" or TEMA "Class C" exchangers shall be governed by the following:
  - a. TEMA "R" is required when:
    - Tube side or shell side fouling factor is greater than 0.00035 m<sup>2</sup>.K/W; or
    - Shell side corrosion allowance is greater than 3.175 mm (1/8 inch);
    - Shell side corrosion rate is greater than 0.254 mm/y (10 mils per year).
  - b. TEMA "C" may be used when exchanger is designed for chemical cleaning maintenance and fouling factor do not exceed 0.00035 m<sup>2</sup>.K/W on both tube side and shell side.

#### 6. Horizontal and Vertical Exchangers

Heat exchangers should be of the horizontal type, however, for process requirements and where cleaning and other maintenance will be infrequent and space requirements make it more attractive, the vertical arrangement may be considered and this should be discussed with the Company. Centerline elevation of the top bundle of stacked exchangers shall be limited to 3.5 m except for large exchangers which shall be limited to two stacked shells.

When horizontal arrangements are preferred, the stacking of exchangers should be considered to conserve space in the structure.

7. The Use of Spiral Plate Heat Exchangers May be Considered When:
  - a. Small overhead or vent condensers mounted directly on process vessels are required.
  - b. Space limitations make use of long shell and tube units impractical.

<b>KLM Technology Group</b>  Project Engineering Standard	<b>PROCESS REQUIREMENTS OF HEAT EXCHANGING EQUIPMENT</b>  <b>(PROJECT STANDARDS AND SPECIFICATIONS)</b>	Page 11 of 54
		Rev: 01
		April 2011

8. Manufacturer's standard for shell and tube heat exchangers may be considered upon approval of the Company and supplied as components of other equipment such as:

- a. Compressor inter/after coolers.
- b. Steam ejector inter/after condensers.
- c. Machinery lube oil coolers.

Fig. A.1 in Appendix A shows different types of shells which has been extracted from TEMA.

9. Selection Guide for Heat Exchanger Types

Table B.1 in Appendix B is also selection guide for heat exchanger types which shows significant feature, applications best suited, limitation and relative cost in carbon steel construction of heat exchangers.

10. Selection of Type

Fixed tube sheet heat exchangers should only be used in services where:

- Differential expansion between the tubes and the shell does not give rise to unacceptable stresses;
- Tube side cleaning, if required, can be don in situ;
- Shell side fluid is non-fouling, or
- Shell side fouling can be removed by chemical cleaning.

U-tube bundle heat exchangers shall only be used in services where:

- Tube side fouling resistance is less than  $0.00035 \text{ (m}^2\cdot\text{K)/W}$ ;
- Tube side fouling can be removed by chemical cleaning.

U-tube shall not be applied when tube side mechanical cleaning is required.

Floating head heat exchangers should be used in all other services except as noted above,

11. Shell Selection

- a. The single-pass shell, Type E (see Fig. A.1 in Appendix A), has the widest application and should be selected for general duties, except where significant advantage can be obtained by using one of the other shell types.
- b. Where the shell side pressure drop is a restricting factor, the divided flow shell Type J or cross flow shell Type X or double-split flow shell Type H, should be considered.

<b>KLM Technology Group</b>  Project Engineering Standard	<b>PROCESS REQUIREMENTS OF HEAT EXCHANGING EQUIPMENT</b>  <b>(PROJECT STANDARDS AND SPECIFICATIONS)</b>	Page 12 of 54
		Rev: 01
		April 2011

- c. For horizontal shell side thermosiphon reboilers, the split flow shell Type G or Type H should be selected.
- d. The kettle type, shell Type K, should be selected for boiling, where an almost 100% vaporization, or where a phase separation is required.
- e. Use of the two-pass shell with longitudinal baffle Type F, should be avoided.

#### 12. Front End and Rear End Selection

- a. Front end bonnet Type B is generally used for heat exchangers where cleaning on the tube side will be infrequent.  
Rear end Type S should be used for floating head heat exchangers.
- b. Rear end Type M should be applied for fixed tube sheet design.
- c. When frequent tube side cleaning is anticipated, and the tube design pressure is low, the front end stationary head shall be Type A, however, for the corresponding rear end, Type may be selected.
- d. For high-pressure and/or very toxic service, where it is desirable to limit the number of external joints, stationary heads Type B, Type C or Type N should be selected for the front end, and the corresponding Type M or Type N for the rear end.
- e. The outside packed floating head Type P, and externally sealed floating tubesheet type W rear ends, are not acceptable.

#### 13. Water-Cooled Coolers

The following restrictions shall apply to water-cooled coolers:

- a. Cooling water shall run upwards through the tubes in order to avoid build up of gas. The tube side velocity shall be as specified in Table 1.
- b. The tube side shall be maintained at an atmospheric over-pressure so that air cannot separate from the water.
- c. In open cooling water systems, the cooling water outlet temperature shall not be higher than 42°C, and to avoid scaling, the tube wall temperature on the cooling water side shall not exceed 52°C.
- d. Internal bellows shall not be applied.
- e. In fouling services, the following additional restrictions apply:
  - In cases where flow control of the water is required, tube side velocities should not be allowed to fall below the values specified in Table 1, in order to avoid deposits of mud, silt or salt.
  - U-tubes shall not be applied.
- f. Shell and tube exchangers using water as the cooling medium are to be avoided when product side temperatures exceed 200°C.